



**Q&A Addendum  
Enterprise Energy Management System  
RFP 600989**

**This document provides question and answer information pertaining to the above captioned RFP and will be updated as necessary.**

**REMINDER:** It is the Respondent's responsibility to thoroughly examine and read the entire RFP document and any appendices and addenda to this RFP.

**Posted April 29, 2016**

**Question:** I have not recognized the pricing section for this bid. The Qualifications make sense, but I cannot seem to see where it equates to pricing.

**Answer:** Please refer to Appendix B – Official Price Sheet. The following list should provide bidders a description of possible system size and complexity. The information is general in nature, only to provide scope of work. It is not meant to be exact:

- 500,000 control points
- 90 buildings each with thermal meters (chilled water, steam, and/or condensate)
  - Many buildings have all three, some have fewer
- 200 electric meters
- 20 production plant meters