



Business Services
1001 East Sain Street | UPTW 101
Fayetteville, Arkansas 72703

IFB08172026

Condenser Water Pumps Package

Q&A Addendum #1

REMINDER: It is the Respondent's responsibility to thoroughly read and examine the entire Bid document and any addenda to the Bid.

Posted 08/26/2026

Question(s) were received from prospective respondents regarding this solicitation. Both the question(s) and the University's response(s) are provided in Q&A Addendum #1 (here) and posted to hogbid.uark.edu.

Q: May we suggest substituting the minimum efficiency with an evaluation factor for KW draw which would allow pumps of lesser efficiency (and perhaps significantly lesser acquisition cost) be evaluated?

A: Pumps with efficiency less than that specified will be considered as long as the flow, head, and max HP requirements are met.